

West Virginia Department of Environmental Protection

Harold D. Ward

Cabinet Secretary

# Permit to Operate



Pursuant to

**Title V**

of the Clean Air Act

*Issued to:*

**Columbia Gas Transmission, LLC**

**Seneca Compressor Station**

**R30-07100008-2023**

*Laura M. Crowder*

---

*Laura M. Crowder*

*Director, Division of Air Quality*

*Issued: August 8, 2023 • Effective: August 22, 2023*  
*Expiration: August 8, 2028 • Renewal Application Due: February 8, 2028*

Permit Number: **R30-07100008-2023**  
Permittee: **Columbia Gas Transmission, LLC**  
Facility Name: **Seneca Compressor Station**  
Permittee Mailing Address: **1700 MacCorkle Ave, SE, Charleston, WV 25314**

---

*This permit is issued in accordance with the West Virginia Air Pollution Control Act (West Virginia Code §§ 22-5-1 et seq.) and 45CSR30 — Requirements for Operating Permits. The permittee identified at the above-referenced facility is authorized to operate the stationary sources of air pollutants identified herein in accordance with all terms and conditions of this permit.*

---

Facility Location:	Seneca Rocks, Pendleton County, West Virginia
Facility Mailing Address:	1 Columbia Lane, Seneca Rocks, WV 26884
Telephone Number:	(304) 567-7500
Type of Business Entity:	LLC
Facility Description:	Natural Gas Transmission Facility
SIC Codes:	4922
UTM Coordinates:	639.5 km Easting • 4,301.10 km Northing • Zone 17

Permit Writer: Beena Modi

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*Issuance of this Title V Operating Permit does not supersede or invalidate any existing permits under 45CSR13, 14 or 19, although all applicable requirements from such permits governing the facility's operation and compliance have been incorporated into the Title V Operating Permit.*

**Table of Contents**

**1.0. Emission Units and Active R13, R14, and R19 Permits..... 3**

**2.0. General Conditions..... 5**

**3.0. Facility-Wide Requirements and Permit Shield .....13**

**Source-specific Requirements**

**4.0. 45CSR13 Permit Conditions from R13-2715F.....21**

**5.0. 40 C.F.R. 60, Subpart JJJJ Requirements for Emergency Reciprocating Internal  
Combustion Engine (RICE) .....30**

**6.0. 40 C.F.R. 60, Subpart KKKK Requirements for Turbines .....34**

## 1.0 Emission Units and Active R13, R14, and R19 Permits

### 1.1 Emission Units

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device
03704*	E04	Turbine Engine/Centrifugal Compressor; General Electric; 3132R Frame 3	1981**	13,750 hp	N/A
03705*	E05	Turbine Engine/Centrifugal Compressor; Solar; Taurus 60-7800S	2008	7,491 hp	N/A
03706*	E06	Turbine Engine/Centrifugal Compressor; Solar; Taurus 60-7800S	2008	7,491 hp	N/A
03707*	E07	Combustion Turbine/Compressor; Solar; Saturn 10-1400	2013	1,557 hp @ 30°F 1,333 hp @ 50°F	N/A
03708*	E08	Combustion Turbine/Compressor; Solar; Mars 100-15000S	2013	15,432 hp @ 30°F 13,814 hp @ 50°F	N/A
03709*	E09	Combustion Turbine/Compressor; Solar; Taurus 70 Turbine	2017	10,613 hp @ 32°F	N/A
037G3*	G3	Reciprocating Engine/Generator Waukesha VGF-L36GL; 4 Cycle, Lean Burn	2013	880 hp	N/A
HTR1*	H1	Fuel Gas Heater; ETI; Model # SB18-18	2008	0.5 mmBtu/hr	N/A
HTR2*	H2	Fuel Gas Heater; ETI; Model # SB18-18	2013	0.5 mmBtu/hr	N/A
HTR3*	H3	Process Heater	2017	0.25 mmBtu/hr	N/A
037SH1*	SH1	Catalytic Space Heaters (36)	2013	2.592 mmBtu/hr (TOTAL)	N/A
037SH2*	SH2	Catalytic Space Heaters (23)	2017	1.12 mmBtu/hr (TOTAL)	N/A

\* All combustion equipment is fired with pipeline quality natural gas only.

\*\* This turbine was originally purchased in 1971, and relocated to Seneca Station in 1981

## 1.2. Active R13, R14, and R19 Permits

The underlying authority for any conditions from R13, R14, and/or R19 permits contained in this operating permit is cited using the original permit number (e.g. R13-1234). The current applicable version of such permit(s) is listed below.

Permit Number	Date of Issuance
R13-2715F	04-26-2016

## 2.0 General Conditions

### 2.1 Definitions

- 2.1.1. All references to the "West Virginia Air Pollution Control Act" or the "Air Pollution Control Act" mean those provisions contained in W.Va. Code §§ 22-5-1 to 22-5-18.
- 2.1.2. The "Clean Air Act" means those provisions contained in 42 U.S.C. §§ 7401 to 7671q, and regulations promulgated thereunder.
- 2.1.3. "Secretary" means the Secretary of the Department of Environmental Protection or other person to whom the Secretary has delegated authority or duties pursuant to W.Va. Code §§ 22-1-6 or 22-1-8 (45CSR§30-2.39.). The Director of the Division of Air Quality is the Secretary's designated representative for the purposes of this permit.
- 2.1.4. Unless otherwise specified in a permit condition or underlying rule or regulation, all references to a "rolling yearly total" shall mean the sum of the monthly data, values or parameters being measured, monitored, or recorded, at any given time for the previous twelve (12) consecutive calendar months.

### 2.2 Acronyms

<b>CAAA</b>	Clean Air Act Amendments	<b>NSPS</b>	New Source Performance Standards
<b>CBI</b>	Confidential Business Information	<b>PM</b>	Particulate Matter
<b>CEM</b>	Continuous Emission Monitor	<b>PM<sub>10</sub></b>	Particulate Matter less than 10µm in diameter
<b>CES</b>	Certified Emission Statement	<b>pph</b>	Pounds per Hour
<b>C.F.R. or CFR</b>	Code of Federal Regulations	<b>ppm</b>	Parts per Million
<b>CO</b>	Carbon Monoxide	<b>PSD</b>	Prevention of Significant Deterioration
<b>C.S.R. or CSR</b>	Codes of State Rules	<b>psi</b>	Pounds per Square Inch
<b>DAQ</b>	Division of Air Quality	<b>SIC</b>	Standard Industrial Classification
<b>DEP</b>	Department of Environmental Protection	<b>SIP</b>	State Implementation Plan
<b>FOIA</b>	Freedom of Information Act	<b>SO<sub>2</sub></b>	Sulfur Dioxide
<b>HAP</b>	Hazardous Air Pollutant	<b>TAP</b>	Toxic Air Pollutant
<b>HON</b>	Hazardous Organic NESHAP	<b>TPY</b>	Tons per Year
<b>HP</b>	Horsepower	<b>TRS</b>	Total Reduced Sulfur
<b>lbs/hr or lb/hr</b>	Pounds per Hour	<b>TSP</b>	Total Suspended Particulate
<b>LDAR</b>	Leak Detection and Repair	<b>USEPA</b>	United States Environmental Protection Agency
<b>m</b>	Thousand	<b>UTM</b>	Universal Transverse Mercator
<b>MACT</b>	Maximum Achievable Control Technology	<b>VEE</b>	Visual Emissions Evaluation
<b>mm</b>	Million	<b>VOC</b>	Volatile Organic Compounds
<b>mmBtu/hr</b>	Million British Thermal Units per Hour		
<b>mmft<sup>3</sup>/hr or mmcf/hr</b>	Million Cubic Feet Burned per Hour		
<b>NA or N/A</b>	Not Applicable		
<b>NAAQS</b>	National Ambient Air Quality Standards		
<b>NESHAPS</b>	National Emissions Standards for Hazardous Air Pollutants		
<b>NO<sub>x</sub></b>	Nitrogen Oxides		

### **2.3. Permit Expiration and Renewal**

- 2.3.1. Permit duration. This permit is issued for a fixed term of five (5) years and shall expire on the date specified on the cover of this permit, except as provided in 45CSR§30-6.3.b. and 45CSR§30-6.3.c.  
**[45CSR§30-5.1.b.]**
- 2.3.2. A permit renewal application is timely if it is submitted at least six (6) months prior to the date of permit expiration.  
**[45CSR§30-4.1.a.3.]**
- 2.3.3. Permit expiration terminates the source's right to operate unless a timely and complete renewal application has been submitted consistent with 45CSR§30-6.2. and 45CSR§30-4.1.a.3.  
**[45CSR§30-6.3.b.]**
- 2.3.4. If the Secretary fails to take final action to deny or approve a timely and complete permit application before the end of the term of the previous permit, the permit shall not expire until the renewal permit has been issued or denied, and any permit shield granted for the permit shall continue in effect during that time.  
**[45CSR§30-6.3.c.]**

### **2.4. Permit Actions**

- 2.4.1. This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.  
**[45CSR§30-5.1.f.3.]**

### **2.5. Reopening for Cause**

- 2.5.1. This permit shall be reopened and revised under any of the following circumstances:
- a. Additional applicable requirements under the Clean Air Act or the Secretary's legislative rules become applicable to a major source with a remaining permit term of three (3) or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 45CSR§§30-6.6.a.1.A. or B.
  - b. Additional requirements (including excess emissions requirements) become applicable to an affected source under Title IV of the Clean Air Act (Acid Deposition Control) or other legislative rules of the Secretary. Upon approval by U.S. EPA, excess emissions offset plans shall be incorporated into the permit.
  - c. The Secretary or U.S. EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
  - d. The Secretary or U.S. EPA determines that the permit must be revised or revoked and reissued to assure compliance with the applicable requirements.

**[45CSR§30-6.6.a.]**

## **2.6. Administrative Permit Amendments**

- 2.6.1. The permittee may request an administrative permit amendment as defined in and according to the procedures specified in 45CSR§30-6.4.  
**[45CSR§30-6.4.]**

## **2.7. Minor Permit Modifications**

- 2.7.1. The permittee may request a minor permit modification as defined in and according to the procedures specified in 45CSR§30-6.5.a.  
**[45CSR§30-6.5.a.]**

## **2.8. Significant Permit Modification**

- 2.8.1. The permittee may request a significant permit modification, in accordance with 45CSR§30-6.5.b., for permit modifications that do not qualify for minor permit modifications or as administrative amendments.  
**[45CSR§30-6.5.b.]**

## **2.9. Emissions Trading**

- 2.9.1. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit and that are in accordance with all applicable requirements.  
**[45CSR§30-5.1.h.]**

## **2.10. Off-Permit Changes**

- 2.10.1. Except as provided below, a facility may make any change in its operations or emissions that is not addressed nor prohibited in its permit and which is not considered to be construction nor modification under any rule promulgated by the Secretary without obtaining an amendment or modification of its permit. Such changes shall be subject to the following requirements and restrictions:
- a. The change must meet all applicable requirements and may not violate any existing permit term or condition.
  - b. The permittee must provide a written notice of the change to the Secretary and to U.S. EPA within two (2) business days following the date of the change. Such written notice shall describe each such change, including the date, any change in emissions, pollutants emitted, and any applicable requirement that would apply as a result of the change.
  - c. The change shall not qualify for the permit shield.
  - d. The permittee shall keep records describing all changes made at the source that result in emissions of regulated air pollutants, but not otherwise regulated under the permit, and the emissions resulting from those changes.
  - e. No permittee may make any change subject to any requirement under Title IV of the Clean Air Act (Acid Deposition Control) pursuant to the provisions of 45CSR§30-5.9.



- f. No permittee may make any changes which would require preconstruction review under any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) pursuant to the provisions of 45CSR§30-5.9.

**[45CSR§30-5.9.]**

## **2.11. Operational Flexibility**

- 2.11.1. The permittee may make changes within the facility as provided by § 502(b)(10) of the Clean Air Act. Such operational flexibility shall be provided in the permit in conformance with the permit application and applicable requirements. No such changes shall be a modification under any rule or any provision of Title I of the Clean Air Act (including 45CSR14 and 45CSR19) promulgated by the Secretary in accordance with Title I of the Clean Air Act and the change shall not result in a level of emissions exceeding the emissions allowable under the permit.

**[45CSR§30-5.8]**

- 2.11.2. Before making a change under 45CSR§30-5.8., the permittee shall provide advance written notice to the Secretary and to U.S. EPA, describing the change to be made, the date on which the change will occur, any changes in emissions, and any permit terms and conditions that are affected. The permittee shall thereafter maintain a copy of the notice with the permit, and the Secretary shall place a copy with the permit in the public file. The written notice shall be provided to the Secretary and U.S. EPA at least seven (7) days prior to the date that the change is to be made, except that this period may be shortened or eliminated as necessary for a change that must be implemented more quickly to address unanticipated conditions posing a significant health, safety, or environmental hazard. If less than seven (7) days notice is provided because of a need to respond more quickly to such unanticipated conditions, the permittee shall provide notice to the Secretary and U.S. EPA as soon as possible after learning of the need to make the change.

**[45CSR§30-5.8.a.]**

- 2.11.3. The permit shield shall not apply to changes made under 45CSR§30-5.8., except those provided for in 45CSR§30-5.8.d. However, the protection of the permit shield will continue to apply to operations and emissions that are not affected by the change, provided that the permittee complies with the terms and conditions of the permit applicable to such operations and emissions. The permit shield may be reinstated for emissions and operations affected by the change:

- a. If subsequent changes cause the facility's operations and emissions to revert to those authorized in the permit and the permittee resumes compliance with the terms and conditions of the permit, or
- b. If the permittee obtains final approval of a significant modification to the permit to incorporate the change in the permit.

**[45CSR§30-5.8.c.]**

- 2.11.4. "Section 502(b)(10) changes" are changes that contravene an express permit term. Such changes do not include changes that would violate applicable requirements or contravene enforceable permit terms and conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements.

**[45CSR§30-2.40]**

## **2.12. Reasonably Anticipated Operating Scenarios**

- 2.12.1. The following are terms and conditions for reasonably anticipated operating scenarios identified in this permit.
- a. Contemporaneously with making a change from one operating scenario to another, the permittee shall record in a log at the permitted facility a record of the scenario under which it is operating and to document the change in reports submitted pursuant to the terms of this permit and 45CSR30.
  - b. The permit shield shall extend to all terms and conditions under each such operating scenario; and
  - c. The terms and conditions of each such alternative scenario shall meet all applicable requirements and the requirements of 45CSR30.

**[45CSR§30-5.1.i.]**

## **2.13. Duty to Comply**

- 2.13.1. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the West Virginia Code and the Clean Air Act and is grounds for enforcement action by the Secretary or USEPA; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**[45CSR§30-5.1.f.1.]**

## **2.14. Inspection and Entry**

- 2.14.1. The permittee shall allow any authorized representative of the Secretary, upon the presentation of credentials and other documents as may be required by law, to perform the following:
- a. At all reasonable times (including all times in which the facility is in operation) enter upon the permittee's premises where a source is located or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
  - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
  - c. Inspect at reasonable times (including all times in which the facility is in operation) any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit;
  - d. Sample or monitor at reasonable times substances or parameters to determine compliance with the permit or applicable requirements or ascertain the amounts and types of air pollutants discharged.

**[45CSR§30-5.3.b.]**

## **2.15. Schedule of Compliance**

- 2.15.1. For sources subject to a compliance schedule, certified progress reports shall be submitted consistent with the applicable schedule of compliance set forth in this permit and 45CSR§30-4.3.h., but at least every six (6) months, and no greater than once a month, and shall include the following:
- a. Dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
  - b. An explanation of why any dates in the schedule of compliance were not or will not be met, and any preventative or corrective measure adopted.

[45CSR§30-5.3.d.]

## **2.16. Need to Halt or Reduce Activity not a Defense**

- 2.16.1. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. However, nothing in this paragraph shall be construed as precluding consideration of a need to halt or reduce activity as a mitigating factor in determining penalties for noncompliance if the health, safety, or environmental impacts of halting or reducing operations would be more serious than the impacts of continued operations.

[45CSR§30-5.1.f.2.]

## **2.17. Reserved**

## **2.18. Federally-Enforceable Requirements**

- 2.18.1. All terms and conditions in this permit, including any provisions designed to limit a source's potential to emit and excepting those provisions that are specifically designated in the permit as "State-enforceable only", are enforceable by the Secretary, USEPA, and citizens under the Clean Air Act.

[45CSR§30-5.2.a.]

- 2.18.2. Those provisions specifically designated in the permit as "State-enforceable only" shall become "Federally-enforceable" requirements upon SIP approval by the USEPA.

## **2.19. Duty to Provide Information**

- 2.19.1. The permittee shall furnish to the Secretary within a reasonable time any information the Secretary may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the Secretary copies of records required to be kept by the permittee. For information claimed to be confidential, the permittee shall furnish such records to the Secretary along with a claim of confidentiality in accordance with 45CSR31. If confidential information is to be sent to USEPA, the permittee shall directly provide such information to USEPA along with a claim of confidentiality in accordance with 40 C.F.R. Part 2.

[45CSR§30-5.1.f.5.]

## **2.20. Duty to Supplement and Correct Information**

- 2.20.1. Upon becoming aware of a failure to submit any relevant facts or a submittal of incorrect information in any permit application, the permittee shall promptly submit to the Secretary such supplemental facts or corrected information.

[45CSR§30-4.2.]

## **2.21. Permit Shield**

- 2.21.1. Compliance with the conditions of this permit shall be deemed compliance with any applicable requirements as of the date of permit issuance provided that such applicable requirements are included and are specifically identified in this permit or the Secretary has determined that other requirements specifically identified are not applicable to the source and this permit includes such a determination or a concise summary thereof.

[45CSR§30-5.6.a.]

- 2.21.2. Nothing in this permit shall alter or affect the following:

- a. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance; or
- b. The applicable requirements of the Code of West Virginia and Title IV of the Clean Air Act (Acid Deposition Control), consistent with § 408 (a) of the Clean Air Act.
- c. The authority of the Administrator of U.S. EPA to require information under § 114 of the Clean Air Act or to issue emergency orders under § 303 of the Clean Air Act.

[45CSR§30-5.6.c.]

## **2.22. Credible Evidence**

- 2.22.1. Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee including but not limited to any challenge to the credible evidence rule in the context of any future proceeding.

[45CSR§30-5.3.e.3.B.]

## **2.23. Severability**

- 2.23.1. The provisions of this permit are severable. If any provision of this permit, or the application of any provision of this permit to any circumstance is held invalid by a court of competent jurisdiction, the remaining permit terms and conditions or their application to other circumstances shall remain in full force and effect.

[45CSR§30-5.1.e.]

## **2.24. Property Rights**

- 2.24.1. This permit does not convey any property rights of any sort or any exclusive privilege.

[45CSR§30-5.1.f.4]

## **2.25. Acid Deposition Control**

- 2.25.1. Emissions shall not exceed any allowances that the source lawfully holds under Title IV of the Clean Air Act (Acid Deposition Control) or rules of the Secretary promulgated thereunder.
- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the acid deposition control program, provided that such increases do not require a permit revision under any other applicable requirement.
  - b. No limit shall be placed on the number of allowances held by the source. The source may not, however, use allowances as a defense to noncompliance with any other applicable requirement.
  - c. Any such allowance shall be accounted for according to the procedures established in rules promulgated under Title IV of the Clean Air Act.

**[45CSR§30-5.1.d.]**

- 2.25.2. Where applicable requirements of the Clean Air Act are more stringent than any applicable requirement of regulations promulgated under Title IV of the Clean Air Act (Acid Deposition Control), both provisions shall be incorporated into the permit and shall be enforceable by the Secretary and U. S. EPA.

**[45CSR§30-5.1.a.2.]**

### 3.0 Facility-Wide Requirements

#### 3.1 Limitations and Standards

- 3.1.1. **Open burning.** The open burning of refuse by any person is prohibited except as noted in 45CSR§6-3.1.  
[45CSR§6-3.1.]
- 3.1.2. **Open burning exemptions.** The exemptions listed in 45CSR§6-3.1 are subject to the following stipulation: Upon notification by the Secretary, no person shall cause or allow any form of open burning during existing or predicted periods of atmospheric stagnation. Notification shall be made by such means as the Secretary may deem necessary and feasible.  
[45CSR§6-3.2.]
- 3.1.3. **Asbestos.** The permittee is responsible for thoroughly inspecting the facility, or part of the facility, prior to commencement of demolition or renovation for the presence of asbestos and complying with 40 C.F.R. § 61.145, 40 C.F.R. § 61.148, and 40 C.F.R. § 61.150. The permittee, owner, or operator must notify the Secretary at least ten (10) working days prior to the commencement of any asbestos removal on the forms prescribed by the Secretary if the permittee is subject to the notification requirements of 40 C.F.R. § 61.145(b)(3)(i). The USEPA, the Division of Waste Management and the Bureau for Public Health - Environmental Health require a copy of this notice to be sent to them.  
[40 C.F.R. §61.145(b) and 45CSR34]
- 3.1.4. **Odor.** No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor at any location occupied by the public.  
[45CSR§4-3.1 State-Enforceable only.]
- 3.1.5. **Standby plan for reducing emissions.** When requested by the Secretary, the permittee shall prepare standby plans for reducing the emissions of air pollutants in accordance with the objectives set forth in Tables I, II, and III of 45CSR11.  
[45CSR§11-5.2]
- 3.1.6. **Emission inventory.** The permittee is responsible for submitting, on an annual basis, an emission inventory in accordance with the submittal requirements of the Division of Air Quality.  
[W.Va. Code § 22-5-4(a)(14)]
- 3.1.7. **Ozone-depleting substances.** For those facilities performing maintenance, service, repair or disposal of appliances, the permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 C.F.R. Part 82, Subpart F, except as provided for Motor Vehicle Air Conditioners (MVACs) in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the prohibitions and required practices pursuant to 40 C.F.R. §§ 82.154 and 82.156.
  - b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 C.F.R. § 82.158.

- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 C.F.R. § 82.161.

**[40 C.F.R. 82, Subpart F]**

- 3.1.8. **Risk Management Plan.** Should this stationary source, as defined in 40 C.F.R. § 68.3, become subject to Part 68, then the owner or operator shall submit a risk management plan (RMP) by the date specified in 40 C.F.R. § 68.10 and shall certify compliance with the requirements of Part 68 as part of the annual compliance certification as required by 40 C.F.R. Part 70 or 71.

**[40 C.F.R. 68]**

- 3.1.9. No person shall cause, suffer, allow or permit fugitive particulate matter to be discharged beyond the boundary lines of the property on which the discharge originates or at any public or residential location, which causes or contributes to statutory air pollution.

**[45CSR§17-3.1; State Enforceable Only]**

- 3.1.10. No person shall cause, suffer, allow or permit emission of smoke and/or particulate matter into the open air from any fuel burning unit which is greater than ten (10) percent opacity based on a six minute block average.

**[45CSR§2-3.1.] [H1]**

### **3.2. Monitoring Requirements**

- 3.2.1. At such reasonable times as the Secretary may designate, the permittee shall conduct visible emissions observations using Method 22 for the purpose of demonstrating compliance with Section 3.1.10. If visible emissions are observed, the permittee shall conduct a Method 9 reading unless the cause for visible emissions is corrected within 24 hours. Records of observation will be kept for at least 5 years from the date of observation.

**[45CSR§30-5.1.c.] [H1]**

### **3.3. Testing Requirements**

- 3.3.1. **Stack testing.** As per provisions set forth in this permit or as otherwise required by the Secretary, in accordance with the West Virginia Code, underlying regulations, permits and orders, the permittee shall conduct test(s) to determine compliance with the emission limitations set forth in this permit and/or established or set forth in underlying documents. The Secretary, or his duly authorized representative, may at his option witness or conduct such test(s). Should the Secretary exercise his option to conduct such test(s), the operator shall provide all necessary sampling connections and sampling ports to be located in such manner as the Secretary may require, power for test equipment and the required safety equipment, such as scaffolding, railings and ladders, to comply with generally accepted good safety practices. Such tests shall be conducted in accordance with the methods and procedures set forth in this permit or as otherwise approved or specified by the Secretary in accordance with the following:

- a. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with 40 C.F.R. Parts 60, 61, and 63, if applicable, in accordance with the Secretary's delegated authority and any established equivalency determination methods which are applicable.
- b. The Secretary may on a source-specific basis approve or specify additional testing or alternative testing to the test methods specified in the permit for demonstrating compliance with applicable requirements which do not involve federal delegation. In specifying or approving such alternative testing to the test

methods, the Secretary, to the extent possible, shall utilize the same equivalency criteria as would be used in approving such changes under Section 3.3.1.a. of this permit.

- c. All periodic tests to determine mass emission limits from or air pollutant concentrations in discharge stacks and such other tests as specified in this permit shall be conducted in accordance with an approved test protocol. Unless previously approved, such protocols shall be submitted to the Secretary in writing at least thirty (30) days prior to any testing and shall contain the information set forth by the Secretary. In addition, the permittee shall notify the Secretary at least fifteen (15) days prior to any testing so the Secretary may have the opportunity to observe such tests. This notification shall include the actual date and time during which the test will be conducted and, if appropriate, verification that the tests will fully conform to a referenced protocol previously approved by the Secretary.
- d. The permittee shall submit a report of the results of the stack test within 60 days of completion of the test. The test report shall provide the information necessary to document the objectives of the test and to determine whether proper procedures were used to accomplish these objectives. The report shall include the following: the certification described in paragraph 3.5.1; a statement of compliance status, also signed by a responsible official; and, a summary of conditions which form the basis for the compliance status evaluation. The summary of conditions shall include the following:
  1. The permit or rule evaluated, with the citation number and language.
  2. The result of the test for each permit or rule condition.
  3. A statement of compliance or non-compliance with each permit or rule condition.

[WV Code §§ 22-5-4(a)(14-15) and 45CSR13]

### 3.4. Recordkeeping Requirements

- 3.4.1. **Monitoring information.** The permittee shall keep records of monitoring information that include the following:
  - a. The date, place as defined in this permit and time of sampling or measurements;
  - b. The date(s) analyses were performed;
  - c. The company or entity that performed the analyses;
  - d. The analytical techniques or methods used;
  - e. The results of the analyses; and
  - f. The operating conditions existing at the time of sampling or measurement.

[45CSR§30-5.1.c.2.A.]

- 3.4.2. **Retention of records.** The permittee shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of monitoring sample, measurement, report, application, or record creation date. Support information includes all calibration and maintenance records



and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Where appropriate, records may be maintained in computerized form in lieu of the above records.

[45CSR§30-5.1.c.2.B.]

- 3.4.3. **Odors.** For the purposes of 45CSR4, the permittee shall maintain a record of all odor complaints received, any investigation performed in response to such a complaint, and any responsive action(s) taken.

[45CSR§30-5.1.c. State-Enforceable only.]

### 3.5. Reporting Requirements

- 3.5.1. **Responsible official.** Any application form, report, or compliance certification required by this permit to be submitted to the DAQ and/or USEPA shall contain a certification by the responsible official that states that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

[45CSR§§30-4.4. and 5.1.c.3.D.]

- 3.5.2. A permittee may request confidential treatment for the submission of reporting required under 45CSR§30-5.1.c.3. pursuant to the limitations and procedures of W.Va. Code § 22-5-10 and 45CSR31.

[45CSR§30-5.1.c.3.E.]

- 3.5.3. Except for the electronic submittal of the annual compliance certification and semi-annual monitoring reports to the DAQ and USEPA as required in 3.5.5 and 3.5.6 below, all notices, requests, demands, submissions and other communications required or permitted to be made to the Secretary of DEP and/or USEPA shall be made in writing and shall be deemed to have been duly given when delivered by hand, or mailed first class or by private carrier with postage prepaid to the address(es), or submitted in electronic format by e-mail as set forth below or to such other person or address as the Secretary of the Department of Environmental Protection may designate:

#### DAQ:

Director  
WVDEP  
Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304

#### US EPA:

Section Chief  
U. S. Environmental Protection Agency, Region III  
Enforcement and Compliance Assurance Division  
Air, RCRA and Toxics Branch (3ED21)  
Four Penn Center  
1600 John F. Kennedy Boulevard  
Philadelphia, PA 19103-2852

#### DAQ Compliance and Enforcement<sup>1</sup>:

DEPAirQualityReports@wv.gov

<sup>1</sup>For all self-monitoring reports (MACT, GACT, NSPS, etc.), stack tests and protocols, Notice of Compliance Status reports, Initial Notifications, etc.

- 3.5.4. **Fees.** The permittee shall pay fees on an annual basis in accordance with 45CSR§30-8.

[45CSR§30-8.]

- 3.5.5. **Compliance certification.** The permittee shall certify compliance with the conditions of this permit on the forms provided by the DAQ. In addition to the annual compliance certification, the permittee may be required to submit certifications more frequently under an applicable requirement of this permit. The annual certification shall be submitted to the DAQ and USEPA on or before March 15 of each year, and shall certify compliance for the period ending December 31. The permittee shall maintain a copy of the certification on site for five (5) years from submittal of the certification. The annual certification shall be submitted in electronic format by e-mail to the following addresses:

**DAQ:**  
DEPAirQualityReports@wv.gov

**US EPA:**  
R3\_APD\_Permits@epa.gov

**[45CSR§30-5.3.e.]**

- 3.5.6. **Semi-annual monitoring reports.** The permittee shall submit reports of any required monitoring on or before September 15 for the reporting period January 1 to June 30 and on or before March 15 for the reporting period July 1 to December 31. All instances of deviation from permit requirements must be clearly identified in such reports. All required reports must be certified by a responsible official consistent with 45CSR§30-4.4. The semi-annual monitoring reports shall be submitted in electronic format by e-mail to the following address:

**DAQ:**  
DEPAirQualityReports@wv.gov

**[45CSR§30-5.1.c.3.A.]**

- 3.5.7. **Reserved.**

- 3.5.8. **Deviations.**

- a. In addition to monitoring reports required by this permit, the permittee shall promptly submit supplemental reports and notices in accordance with the following:
1. Reserved.
  2. Any deviation that poses an imminent and substantial danger to public health, safety, or the environment shall be reported to the Secretary immediately by telephone or email. A written report of such deviation, which shall include the probable cause of such deviation, and any corrective actions or preventative measures taken, shall be submitted by the responsible official within ten (10) days of the deviation.
  3. Deviations for which more frequent reporting is required under this permit shall be reported on the more frequent basis.
  4. All reports of deviations shall identify the probable cause of the deviation and any corrective actions or preventative measures taken.

**[45CSR§30-5.1.c.3.C.]**

- b. The permittee shall, in the reporting of deviations from permit requirements, including those attributable to upset conditions as defined in this permit, report the probable cause of such deviations and any corrective actions or preventive measures taken in accordance with any rules of the Secretary.  
**[45CSR§30-5.1.c.3.B.]**

- 3.5.9. **New applicable requirements.** If any applicable requirement is promulgated during the term of this permit, the permittee will meet such requirements on a timely basis, or in accordance with a more detailed schedule if required by the applicable requirement.  
**[45CSR§30-4.3.h.1.B.]**

**3.6. Compliance Plan**

- 3.6.1. None

**3.7. Permit Shield**

- 3.7.1. The permittee is hereby granted a permit shield in accordance with 45CSR§30-5.6. The permit shield applies provided the permittee operates in accordance with the information contained within this permit.
- 3.7.2. The following requirements specifically identified are not applicable to the source based on the determinations set forth below. The permit shield shall apply to the following requirements provided the conditions of the determinations are met.

<b>45CSR4</b>	<i>To Prevent and Control the Discharge of Air Pollutants into the Open Air Which Cause or Contributes to an Objectionable Odor or Odors:</i> This State Rule shall not apply to the following source of objectionable odor until such time as feasible control methods are developed: Internal combustion engines.
<b>45CSR10</b>	<i>To Prevent and Control Air Pollution from the Emission of Sulfur Dioxide - Emissions from Indirect Heat Exchangers.</i> WVDAQ has determined that 45CSR10 does not apply to natural gas fired engines. Also, the requirements for fuel burning units does not apply to HTR1, HTR2, and HTR3 because they have design heat inputs less than 10 mmBtu/hr and are exempt in accordance with 45CSR§10-10.1. The catalytic space heaters are not defined as fuel burning units.
<b>45CSR21</b>	<i>To Prevent and Control Air Pollution from the Emission of Volatile Organic Compounds:</i> The facility is not located in a designated VOC County. Therefore, this State Rule does not apply.
<b>45CSR27</b>	<i>To Prevent and Control the Emissions of Toxic Air Pollutants:</i> Natural gas is included as a petroleum product and contains less than 5% benzene by weight. 45CSR§27-2.4 exempts equipment “used in the production and distribution of petroleum products providing that such equipment does not produce or contact materials containing more than 5% benzene by weight.”
<b>40 C.F.R. Part 60 Subpart OOOO</b>	<i>Standards of Performance for Crude Oil and Natural Gas Facilities.</i> The facility does not meet the § 60.5430 definition of a Crude Oil and Natural Gas Production source category. Therefore, 40 C.F.R. Part 60 Subpart OOOO does not apply.

<b>40 CFR 60 Subpart OOOOa</b>	<i>Standards of Performance for Crude Oil and Natural Gas Facilities for which Construction, Modification, or Reconstruction Commenced after September 18, 2015.</i> The permittee has demonstrated to the WV Division of Air Quality that construction commenced on the Combustion Turbine/Compressor (Emission Point ID- E09) prior to the September 18, 2015, applicability date of 40 CFR 60 Subpart OOOOa. Therefore, the facility is not subject to the leak detection and repair requirements of this regulation.
<b>40 C.F.R. Part 60 Subpart K and Ka</b>	<i>Standards of Performance for Petroleum Liquid Storage Vessels.</i> All tanks at the station are below the applicability criteria of 40,000 gallons in capacity as stated in 40CFR§§60.110(a) and 60.110(a).
<b>40 C.F.R. Part 60 Subpart Kb</b>	<i>Standards of Performance for Volatile Organic Liquid Storage Vessels.</i> All tanks at the station are below the applicability criteria of 75m <sup>3</sup> (19,813 gallons) in capacity as stated in 40CFR§60.110b(a).
<b>40 C.F.R. Part 60 Subpart Dc</b>	<i>Standards of Performance for Steam Generating Units:</i> The fuel gas heaters have a maximum design heat input capacity of less than 10 MMBtu/hr, which is below the applicability threshold defined within 40CFR§60.40c(a).
<b>40 C.F.R. Part 60 Subpart GG</b>	<i>Standards of Performance for Stationary Turbines:</i> The provisions of this subpart are not applicable because the turbines were installed after the applicability dates and are therefore, subject to 40 C.F.R. 60 Subpart KKKK. The only exception is the GE Frame 3 Turbine (ID 03704) which was installed in 1981, but as a relocated unit originally purchased in 1971. Therefore, the unit is not considered a new construction or modification in accordance with the General Provisions, 40CFR§60.14(e)(6).
<b>40 C.F.R. Part 60 Subpart IIII</b>	<i>Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.</i> The compressor station does not have any compression ignition internal combustion engines.
<b>40 C.F.R. Part 63 Subpart HHH</b>	<i>National Emission Standards for Hazardous Air Pollutants from Natural Gas Transmission and Storage Facilities.</i> The compressor station is not subject to Subpart HHH since it is not a major source of HAPs and it does not incorporate dehydration operations.
<b>40 C.F.R. Part 63 Subpart YYYY</b>	National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines does not apply to this station since it does not exceed major source HAP thresholds.
<b>40 C.F.R. Part 63 Subpart DDDDD</b>	National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters does not apply to this station since it does not exceed major source HAP thresholds.
<b>40 C.F.R. Part 63 Subpart JJJJJJ</b>	<i>National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources.</i> The facility is not subject to 40 C.F.R. Part 63 Subpart JJJJJJ since the fuel gas heaters and process heater are not boilers, but process heaters, which are not regulated under this source category.
<b>40 C.F.R. Part 64</b>	<i>Compliance Assurance Monitoring.</i> The compliance assurance monitoring provisions of Part 64 are not applicable due to there being no add-on controls at this facility per 40CFR§64.2(a)(2).

### **3.8 Emergency Operating Scenario**

For emergency situations which interrupt the critical supply of natural gas to the public, and which pose a life threatening circumstance to the customer, the permittee is allowed to temporarily replace failed engine(s) as long as all of the following conditions are met:

- a. The replacement engine(s) is only allowed to operate until repair of the failed engine(s) is complete, but under no circumstance may the replacement engine(s) operate in excess of sixty (60) days;
- b. Both the replacement engine(s) and the repaired failed engine(s) shall not operate at the same time with the exception of any necessary testing of the repaired engine(s) and this testing may not exceed five (5) hours;
- c. Potential hourly emissions from the replacement engine(s) are less than or equal to the potential hourly emissions from the engine(s) being replaced;
- d. Credible performance emission test data verifying the emission rates associated with the operation of the substitute engine shall be submitted to the Director within five (5) days;
- e. The permittee must provide written notification to the Director within five (5) days of the replacement. This notification must contain:
  - i. Information to support the claim of life threatening circumstances to justify applicability of this emergency provision;
  - ii. Identification of the engine(s) being temporarily replaced;
  - iii. The design parameters of the replacement engine(s) including, but not limited to, the design horsepower and emission factors;
  - iv. Projected duration of the replacement engine(s); and
  - v. The appropriate certification by a responsible official.

**[45CSR§30-12.7]**

**4.0 45CSR13 Permit Conditions from R13-2715F [Emission Point ID(s): (H2, H3, E05, E06, E07, E08, E09, G3, SH1, and SH2)]**

**4.1. Limitations and Standards**

4.1.1. Annual emissions from the two Solar Taurus 60-7800S turbines (E05 & E06) shall not exceed the following:

	NO	CO	VOC	SO <sub>2</sub>	PM <sub>10</sub>	CH <sub>2</sub> O
	tpy	tpy	tpy	tpy	tpy	tpy
E05	18.79	50.5	14.15	0.21	1.96	0.21
E06	18.79	50.5	14.15	0.21	1.96	0.21
Total	37.6	101.0	28.3	0.42	3.92	0.42

**[45CSR13; Permit R13-2715, Condition 4.1.1]**

4.1.2. The two Solar Taurus 60-7800S turbines (E05 & E06) shall combust only pipeline quality natural gas which contains a maximum of 20 grains of sulfur per 100 scf.

**[40 CFR §60.4365(a); 45CSR16, 45CSR13; Permit R13-2715, Condition 4.1.2]**

4.1.3. Each of the two Solar Taurus 60-7800S turbines (E05 & E06) shall consume no more than 75,916 cubic feet of natural gas per hour nor  $6.00 \times 10^8$  scf of natural gas per year.

**[45CSR13; Permit R13-2715, Condition 4.1.3]**

4.1.4. Emissions from the two Solar Taurus 60-7800S turbines (E05 & E06) shall not exceed the following:

Pollutant	E05	E06
<b>NO<sub>x</sub></b>		
Full Load @ $\geq 0^\circ\text{F}$	25 ppm <sub>v</sub> @ 15% O <sub>2</sub> / 3.8 lb/hr	25 ppm <sub>v</sub> @ 15% O <sub>2</sub> / 3.8 lb/hr
Low Temp (<0 to -20°F)	11 lb/hr	11 lb/hr
Very Low Temp (< -20°F)	31.6 lb/hr	31.6 lb/hr
Startup/Shutdown	3.9 lb/hr	3.9 lb/hr
Low Load (< 50%)	10.3 lb/hr	10.3 lb/hr
<b>SO<sub>2</sub></b>		
Full Load	0.5 lb/hr	0.5 lb/hr
Startup/Shutdown	0.05 lb/hr	0.05 lb/hr
Low Load (< 50%)	0.3 lb/hr	0.3 lb/hr
<b>Pollutant</b>	<b>E05</b>	<b>E06</b>

Pollutant	E05	E06
<b>CO</b>		
Full Load @ $\geq 0^{\circ}\text{F}$	3.9 lb/hr	3.9 lb/hr
Low Temp (< 0 to -20F)	15.9 lb/hr	15.9 lb/hr
Very Low Temp (< -20F)	24.1 lb/hr	24.1 lb/hr
Startup/Shutdown	72.0 lb/hr	72.0 lb/hr
Low Load (< 50%)	196.5 lb/hr	196.5 lb/hr
<b>VOC</b>		
Full Load @ $\geq 0^{\circ}\text{F}$	0.2 lb/hr	0.2 lb/hr
Low Temp (< 0 to -20F)	0.5 lb/hr	0.5 lb/hr
Very Low Temp (< -20F)	0.7 lb/hr	0.7 lb/hr
Startup/Shutdown	711.2 lb/hr	711.2 lb/hr
Low Load (< 50%)	1.5 lb/hr	1.5 lb/hr
<b>PM<sub>10</sub></b>		
Full Load @ $\geq 0^{\circ}\text{F}$	0.5 lb/hr	0.5 lb/hr
Startup/Shutdown	0.3 lb/hr	0.3 lb/hr
Low Load (< 50%)	0.3 lb/hr	0.3 lb/hr

**[45CSR13; Permit R13-2715, Condition 4.1.4]**

4.1.5. Emissions from turbine E07, turbine E08, turbine E09, emergency generator G3, fuel gas heater H2, fuel gas heater H3, 36 combined space heaters SH1, and 23 combined space heaters SH2 shall not exceed the following:

	NO <sub>x</sub>		CO		VOC		SO <sub>2</sub>		PM/PM <sub>10</sub> /PM <sub>2.5</sub>	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
E07	9.48	41.51	15.39	67.63	0.44	1.94	1.00	0.05	0.32	1.32
E08	6.76	31.83	6.85	63.02	0.79	3.88	7.14	0.37	2.25	9.42
E09	4.74	22.80	4.81	91.80	0.55	3.22	5.01	0.27	0.58	2.53
G3	3.88	0.97	2.52	0.63	0.08	0.02	0.39	0.01	0.07	0.02
H2	0.08	0.37	0.07	0.31	0.01	0.02	0.05	0.01	0.01	0.03
H3	0.02	0.11	0.02	0.09	0.01	0.01	0.01	0.01	0.01	0.01
SH1 (36)	0.25	1.11	0.21	0.93	0.02	0.06	0.15	0.01	0.02	0.08
SH2 (23)	0.11	0.48	0.09	0.40	0.01	0.03	0.06	0.01	0.01	0.04

Note: Maximum hourly emission rate based on 30°F for E07 and E08  
 Maximum hourly emission rate based on 32°F for E09

Emission Point ID	CO <sub>2</sub> e
	tpy
E07	8,576
E08	61,264
E09	44,975
G3	200
H2	436
H3	128
SH1 (36)	1,329
SH2 (23)	574

**[45CSR13; Permit R13-2715, Condition 4.1.5]**

4.1.6. The Solar Mars 100-15000S turbine (E08), the Solar Saturn 10-1400 turbine (E07), the Solar Taurus 70 turbine (E09) and the Dresser-Waukesha VGF-L36GL emergency generator (G3) shall combust only pipeline quality natural gas which contains a maximum of 20 grains of sulfur per 100 scf and which contains a maximum of 0.25 grains of sulfur per 100 scf as averaged over a rolling period of twelve (12) months. **[40 CFR §60.4365(a), 45CSR§13-5.10, 45CSR16, 45CSR13; Permit R13-2715, Condition 4.1.6]**

4.1.7. The Solar Mars 100-15000S turbine (E08), the Solar Saturn 10-1400 turbine (E07) and the Solar Taurus 70 turbine (E09) shall consume no more than the following amounts of natural gas:

Emission Point ID	Natural gas consumption	
	scf/hr	scf/yr
E07	17,216	143.61 X 10 <sup>6</sup>
E08	122,525	1,025.86 X 10 <sup>6</sup>
E09	85,971	753.1 X 10 <sup>6</sup>

Note: E07 and E08 hourly natural gas consumption is based on 30 °F, E09 hourly and annual natural gas consumption is based on 32 °F and annual natural gas consumption is based on 50 °F.

**[45CSR13; Permit R13-2715, Condition 4.1.7]**

4.1.8. Emissions from the Solar Mars 100-15000S turbine (E08), the Solar Saturn 10-1400 turbine (E07) and the Solar Taurus 70 turbine (E09) shall not exceed the following:



Pollutant	E08	E07
<b>NO<sub>x</sub></b>		
Full Load@30°F	25 ppm <sub>v</sub> @ 15% O <sub>2</sub> / 6.76 lb/hr	150 ppm <sub>v</sub> @ 15% O <sub>2</sub> / 9.48 lb/hr
Low Temp (< 0 to -20°F)	20.58 lb/hr	10.36 lb/hr
Very Low Temp (< -20°F)	58.80 lb/hr	10.36 lb/hr
Startup/Shutdown	3.1 lb/cycle	1.44 lb/cycle
Low Load (< 50%)	16.10 lb/hr	5.67 lb/hr
<b>SO<sub>x</sub></b> (short term emission rate based on 20 gr S/100 scf)		
Full Load	7.14 lb/hr	1.00 lb/hr
Startup/Shutdown	7.14 lb/hr	1.00 lb/hr
Low Load (< 50%)	7.14 lb/hr	1.00 lb/hr
<b>CO</b>		
Full Load @30°F	6.85 lb/hr	15.39 lb/hr
Low Temp (< 0 to -20°F)	29.83 lb/hr	16.82 lb/hr
Very Low Temp (< -20°F)	44.74 lb/hr	16.82 lb/hr
Startup/Shutdown	272.70 lb/cycle	4.44 lb/cycle
Low Load (< 50%)	653.4 lb/hr	14.37 lb/hr
<b>VOC</b>		
Full Load @30°F	0.79 lb/hr	0.44 lb/hr
Low Temp (< 0 to -20°F)	1.70 lb/hr	0.48 lb/hr
Very Low Temp (< -20°F)	1.70 lb/hr	0.48 lb/hr
Startup/Shutdown	3.12 lb/cycle	0.23 lb/cycle
Low Load (< 50%)	7.47 lb/hr	0.66 lb/hr
<b>PM<sub>10</sub></b>		
Full Load @30°F	2.25 lb/hr	0.32 lb/hr
Startup/Shutdown	2.25 lb/hr	0.32 lb/hr
Low Load (< 50%)	2.25 lb/hr	0.32 lb/hr

Pollutant	E09
<b>NO<sub>x</sub></b>	
Full Load @ 32°F	15 ppm <sub>v</sub> @ 15% O <sub>2</sub> /4.74 lb/hr
Low Temp (< 0°F)	14.21 lb/hr
Low Load (< 50%)	14.45 lb/hr
Startup/Shutdown	1.90 lb/cycle
<b>SO<sub>x</sub></b> (short term emission rate based on 20 gr S/100 scf)	
Full Load @ 32°F	5.01 lb/hr
Startup/Shutdown	5.01 lb/hr
Low Load (< 50%)	5.01 lb/hr
<b>CO</b>	
Full Load @ 32°F	4.81 lb/hr
Low Temp (< 0 °F)	20.59 lb/hr
Low Load (< 50%)	586.42 lb/hr
Startup/Shutdown	166.50 lb/cycle
<b>VOC</b>	
Full Load @ 32°F	0.55 lb/hr
Low Temp (< 0°F)	1.18 lb/hr
Low Load (< 50%)	6.70 lb/hr
Startup/Shutdown	1.90 lb/cycle
<b>PM<sub>10</sub></b>	
Full Load @ 32°F	0.58 lb/hr
Startup/Shutdown	0.58 lb/hr
Low Load (< 50%)	0.58 lb/hr

**[45CSR13; Permit R13-2715, Condition 4.1.8]**

4.1.9. Emergency Generator G3 shall not operate more than 500 hours per year based on a rolling 12 month total.  
**[45CSR13; Permit R13-2715, Condition 4.1.9]**

4.1.10. The MDHI of the fuel gas heater (H2) shall not exceed 0.85mmBtu/hr and the unit shall only be fired by natural gas. The MDHI of the fuel gas heater (H3) shall not exceed 0.25 mmBtu/hr and the unit shall only be fired by natural gas.

**[45CSR13; Permit R13-2715, Condition 4.1.10]**

- 4.1.11. No person shall cause, suffer, allow or permit emission of smoke and/or particulate matter into the open air from any fuel burning unit which is greater than ten (10) percent opacity based on a six minute block average.  
**[45CSR13; Permit R13-2715, Condition 4.1.11, 45CSR§2-3.1.]**
- 4.1.12. The MDHI for each of the 36 catalytic space heaters (SH1) shall not exceed 0.072 MMBTU/hr. The MDHI for each of the 23 catalytic space heaters (SH2) shall not exceed 8 units@ 0.005 MMBTU/hr and 15 units@ 0.072 MMBTU/hr;  
**[45CSR13; Permit R13-2715, Condition 4.1.12]**
- 4.1.13. **Operation and Maintenance of Air Pollution Control Equipment.** The permittee shall, to the extent practicable, install, maintain, and operate all pollution control equipment listed in Section 1.0 and associated monitoring equipment in a manner consistent with safety and good air pollution control practices for minimizing emissions, or comply with any more stringent limits set forth in this permit or as set forth by any State rule, Federal regulation, or alternative control plan approved by the Secretary.  
**[45CSR13; Permit R13-2715, Condition 4.1.17, 45CSR§13-5.10]**
- 4.1.14. The permittee shall install, maintain, and operate all above-ground piping, valves, pumps, etc. that service lines in the transport of potential sources of regulated air pollutants to prevent any substantive fugitive escape of regulated air pollutants. Any above-ground piping, valves, pumps, etc. that shows signs of excess wear and that have a reasonable potential for substantive fugitive emissions of regulated air pollutants shall be repaired or replaced as needed.  
**[45CSR13; Permit R13-2715, Condition 4.1.18]**

## 4.2 Monitoring Requirements

- 4.2.1 At such reasonable times as the Secretary may designate, the permittee shall conduct visible emissions observations using Method 22 for the purpose of demonstrating compliance with Section 4.1.11. If visible emissions are observed, the permittee shall conduct a Method 9 reading unless the cause for visible emissions is corrected within 24 hours. Records of observation will be kept for at least 5 years from the date of observation.  
**[45CSR§30-5.1.c.]**

### 4.3. Testing Requirements

- 4.3.1. In order to show compliance with the CO emission limits contained in 4.1.1, 4.1.4, 4.1.5 and 4.1.8 of this permit the permittee shall perform initial and periodic performance tests on each turbine using EPA approved methods (or other alternative methods approved by the Director). Said testing shall be performed while the turbines are operating at normal conditions, within 25% of full load or at the highest achievable load (and while ambient temperatures are above 0°F). The initial performance test shall be conducted within 180 days of startup. Subsequent testing shall be conducted at least every 5 years. **[45CSR13; Permit R13-2715, Condition 4.2.2]**
- 4.3.2. In order to show compliance with the NO<sub>x</sub> emission limits contained in 4.1.1, 4.1.4, 4.1.5 and 4.1.8 of this permit the permittee must perform an initial and annual performance tests in accordance with §60.4400 to demonstrate continuous compliance. If the NO<sub>x</sub> emission result from the performance test is less than or equal to 75 percent of the NO<sub>x</sub> emission limit contained in 4.1.4 of this permit, the permittee may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NO<sub>x</sub> emission limit for the turbines, the permittee must resume annual performance tests. The initial performance test shall be conducted within 60 days after achieving full-load operation or within 180 days of startup whichever comes first. **[45CSR13; Permit R13-2715, Condition 4.2.1]**

### 4.4. Recordkeeping Requirements

- 4.4.1. **Record of Monitoring.** The permittee shall keep records of monitoring information that include the following:
- a. The date, place as defined in this permit and time of sampling or measurements;
  - b. The date(s) analyses were performed;
  - c. The company or entity that performed the analyses;
  - d. The analytical techniques or methods used;
  - e. The results of the analyses; and
  - f. The operating conditions existing at the time of sampling or measurement.
- [45CSR13; Permit R13-2715, Condition 4.3.1]**
- 4.4.2. **Record of Malfunctions of Air Pollution Control Equipment.** For all air pollution control equipment listed in Section 1.0, the permittee shall maintain records of the occurrence and duration of any malfunction or operational shutdown of the air pollution control equipment during which excess emissions occur. For each such case, the following information shall be recorded:
- a. The equipment involved.
  - b. Steps taken to minimize emissions during the event.
  - c. The duration of the event.
  - d. The estimated increase in emissions during the event.

For each such case associated with an equipment malfunction, the additional information shall also be recorded:

- e. The cause of the malfunction.
- f. Steps taken to correct the malfunction.
- g. Any changes or modifications to equipment or procedures that would help prevent future recurrences of the malfunction.

**[45CSR13; Permit R13-2715, Condition 4.3.2]**

- 4.4.3. In order to demonstrate compliance with conditions 4.1.3 and 4.1.7 of this permit, the permittee shall monitor and record the amount of natural gas consumed by each piece of equipment.

**[45CSR13; Permit R13-2715, Condition 4.3.3]**

- 4.4.4. In order to demonstrate compliance with the emission limitations of conditions 4.1.1, 4.1.4, 4.1.5 and 4.1.8 of this permit the permittee will monitor and record the following:

- a. Monthly operating hours of the turbines at normal dry low NO<sub>x</sub> (DLN) conditions ( $\geq 50\%$  of rated load and ambient temperatures of  $\geq 0^\circ\text{F}$ ).
- b. Monthly operating hours of the turbines at low load ( $\leq 50\%$  load).
- c. Monthly operating hours of the turbines at low ambient temperature ( $< 0$  to  $-20^\circ\text{F}$ ).
- d. Monthly operating hours of the turbines at very low temperature ( $< -20^\circ\text{F}$ ).
- e. Monthly operating hours of turbine startup and shutdown cycles.
- f. Monthly total operating hours of each turbine and emergency generator G3.

**[45CSR13; Permit R13-2715, Condition 4.3.4]**

- 4.4.5. The monthly records required by condition 4.4.4 of this permit shall be used to calculate monthly emissions for each regulated pollutant (Px) using the following equation for turbines E05, E06, E07, E08 and E09:

$$PT = \text{DLN Px} * \text{DLN hours} + \text{LL Px} * \text{LL hours} + \text{LT Px} * \text{LT hours} + \text{VLT Px} * \text{VLT hours} + \text{SS Px} * \text{SS cycles}$$

Where, PT is the total tons of emissions for the month, DLN Px, LL Px, LT Px, VLT Px, and SS Px are the unit emission rates for pollutant X during normal DLN, low-load, low temperature, very low temperature and startup/shutdown operation respectively. DLN hours, LL hours, LT hours, VLT hours, and SS hours are the unit monthly operating hours at DLN, low-load, low temperature, very low temperature and startup/shutdown conditions respectively. The unit emission rates for each pollutant are the emission limits contained in conditions 4.1.4 and 4.1.8 of this permit.

**[45CSR13; Permit R13-2715, Condition 4.3.5]**

- 4.4.6. The monthly records required by condition 4.4.4 of this permit shall be used to calculate monthly emissions for each regulated pollutant (Px) using the following equation for the emergency generator (G3), fuel gas heaters (H2, H3) and catalytic heaters.

$$PT = \text{Px} * \text{total monthly operating hours}$$

Where,  $P_T$  is the total tons of emissions for the month, and  $P_x$  is the unit emission rate for pollutant X during normal operation. The unit emission rates for each pollutant are the emission limits contained in condition 4.1.5 of this permit.

**[45CSR13; Permit R13-2715, Condition 4.3.6]**

- 4.4.7. At the end of each month, the monthly emissions will be calculated for the preceding 12 months to determine compliance with the annual emission limits. **[45CSR13; Permit R13-2715, Condition 4.3.7]**
- 4.4.8. In order to determine compliance with 4.1.9 of this permit, the permittee shall maintain monthly records of the number of hours of operation of the Emergency Generator G3. **[45CSR13; Permit R13-2715, Condition 4.3.8]**

#### **4.5. Reporting Requirements**

- 4.5.1. The permittee shall comply with all applicable reporting requirements of 40 CFR 60 Subparts JJJJ and KKKK. **[45CSR13; Permit R13-2715, Condition 4.4.1]**
- 4.5.2. Any deviation(s) from the allowable natural gas consumption limits of conditions 4.1.3, and 4.1.7 shall be reported in writing to the Director of the Division of Air Quality as soon as practicable, but in any case within ten (10) calendar days of the occurrence and shall include at least the following information: the extent of the deviation, the cause or suspected cause of the deviation(s), and any corrective measures taken or planned. **[45CSR13; Permit R13-2715, Condition 4.4.2]**
- 4.5.3. Any deviation(s) from the allowable emission limits of conditions 4.1.1, 4.1.4, 4.1.5 and 4.1.8 shall be reported in writing to the Director of the Division of Air Quality as soon as practicable, but in any case within ten (10) calendar days of the occurrence and shall include at least the following information: the extent of the deviation, the cause or suspected cause of the deviation(s), and any corrective measures taken or planned. **[45CSR13; Permit R13-2715, Condition 4.4.3]**
- 4.5.4. Any deviation(s) from the allowable hours of operation limits of condition 4.1.9 shall be reported in writing to the Director of the Division of Air Quality as soon as practicable, but in any case within ten (10) calendar days of the occurrence and shall include at least the following information: the extent of the deviation, the cause or suspected cause of the deviation(s), and any corrective measures taken or planned. **[45CSR13; Permit R13-2715, Condition 4.4.4]**
- 4.5.5. Any deviation(s) from the allowable visible emission requirement for any emission source discovered during observations using 40CFR Part 60, Appendix A, Method 9 or 22 shall be reported in writing to the Director of the Division of Air Quality as soon as practicable, but in any case within ten (10) calendar days of the occurrence and shall include at least the following information: the results of the visible determination of opacity of emissions, the cause or suspected cause of the deviation(s), and any corrective measures taken or planned. **[45CSR13; Permit R13-2715, Condition 4.4.5]**

**5.0 40 C.F.R. 60, Subpart JJJJ Requirements for Emergency Reciprocating Internal Combustion Engine (RICE) [emission point ID(s): G3]**

**5.1. Limitations and Standards**

5.1.1. Emissions from Emergency Generator G05 shall not exceed the following:

NSPS JJJJ –Limits	NOx	CO	VOC
Standard (g/Hp hr)	2.0	4.0	1.0

**[45CSR16; 40CFR§60.4233(e) and Table 1 of 40 C.F.R. 60, Subpart JJJJ, 45CSR13; Permit R13-2715, Condition 4.1.13]**

5.1.2. The permittee must install a non-resettable hour meter.

**[45CSR16; 40CFR§60.4237(a)]**

5.1.3. If you own or operate an emergency stationary ICE, you must operate the emergency stationary ICE according to the requirements in paragraphs (a) through (c) of this section. In order for the engine to be considered an emergency stationary ICE under this subpart, any operation other than emergency operation, maintenance and testing, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (a) through (c) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (a) through (c) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

- a. There is no time limit on the use of emergency stationary ICE in emergency situations.
- b. You may operate your emergency stationary ICE for the purpose specified in paragraph (b)(1) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (c) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (b).
  - 1. Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.
- c. Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in paragraph (b) of this section. Except as provided in paragraph (c)(1) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

1. The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:
  - i. The engine is dispatched by the local balancing authority or local transmission and distribution system operator;
  - ii. The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
  - iii. The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
  - iv. The power is provided only to the facility itself or to support the local transmission and distribution system.
  - v. The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

**[45CSR16; 40CFR§60.4243(d)]**

- 5.1.4. The permittee must operate and maintain the stationary SI ICE as required in 40CFR§60.4233 over the entire life of the engine.

**[45CSR16; 40CFR§60.4234]**

- 5.1.5. Owners and operators of stationary SI natural gas fired engines may operate their engines using propane for a maximum of 100 hours per year as an alternative fuel solely during emergency operations, but must keep records of such use. If propane is used for more than 100 hours per year in an engine that is not certified to the emission standards when using propane, the owners and operators are required to conduct a performance test to demonstrate compliance with the emission standards of 40CFR§60.4233.

**[45CSR16; 40CFR§60.4243(e)]**

## **5.2. Monitoring Requirements**

- 5.2.1. If you are an owner or operator of a stationary SI internal combustion engine and must comply with the emission standards specified in 40CFR§60.4233(d) or (e), you must demonstrate compliance according to the methods specified in the following paragraphs:

- a. Purchasing a non-certified engine and demonstrating compliance with the emission standards specified in 40CFR§§60.4233(d) or (e) and according to the requirements specified in 40CFR§60.4244, as applicable, and according to the following paragraph:

**[40CFR§60.4243(b)(2)]**

1. If you are an owner or operator of a stationary SI internal combustion engine greater than 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test and conduct subsequent performance testing every 8,760 hours or 3 years, whichever comes first, thereafter to demonstrate compliance.

**[40CFR§60.4243(b)(2)(ii)]**

**[45CSR16; 40CFR§60.4243(b)(2) and 45CSR13; Permit R13-2715, Condition 4.3.9]**



### 5.3. Testing Requirements

- 5.3.1. Owners and operators of stationary SI ICE who conduct performance tests must follow the procedures in 40 C.F.R. §60.4244.  
**[45CSR16; 40CFR§60.4244]**

### 5.4. Recordkeeping Requirements

- 5.4.1. Owners and operators of all stationary SI ICE must keep records of the information in paragraphs (a) through (c) of this section.
- a. All notifications submitted to comply with this subpart and all documentation supporting any notification.
  - b. Maintenance conducted on the engine.
  - c. If the stationary SI internal combustion engine is not a certified engine or is a certified engine operating in a non-certified manner and subject to 40CFR§60.4243(a)(2), documentation that the engine meets the emission standards.

**[45CSR16; 40CFR§§60.4245(a)(1), (2), and (4)]**

- 5.4.2. For all stationary SI emergency ICE greater than or equal to 500 HP manufactured on or after July 1, 2010, that do not meet the standards applicable to non-emergency engines, the owner or operator of must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter.

The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for non-emergency operation.

**[45CSR16; 40CFR§60.4245(b)]**

### 5.5. Reporting Requirements

- 5.5.1. Owners and operators of stationary SI ICE that are subject to performance testing must submit a copy of each performance test as conducted in §60.4244 within 60 days after the test has been completed. Performance test reports using EPA Method 18, EPA Method 320, or ASTM D6348-03 (incorporated by reference—see 40 CFR 60.17) to measure VOC require reporting of all QA/QC data. For Method 18, report results from sections 8.4 and 11.1.1.4; for Method 320, report results from sections 8.6.2, 9.0, and 13.0; and for ASTM D6348-03 report results of all QA/QC procedures in Annexes 1-7.  
**[45CSR16; 40CFR§60.4245(d)]**

- 5.5.2. If you own or operate an emergency stationary SI ICE with a maximum engine power more than 100 HP that operates for the purpose specified in 40CFR§60.4243(d)(3)(i), you must submit an annual report according to the requirements in paragraphs (a) through (c) of this section.

- a. The report must contain the following information:
  1. Company name and address where the engine is located.

2. Date of the report and beginning and ending dates of the reporting period.
  3. Engine site rating and model year.
  4. Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
  5. Reserved.
  6. Reserved.
  7. Hours spent for operation for the purposes specified in 40CFR§60.4243(d)(3)(i), including the date, start time, and end time for engine operation for the purposes specified in 40CFR§60.4243(d)(3)(i). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.
- b. The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.
  - c. The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in 40CFR§60.4.

[45CSR16; 40CFR§60.4245(e)]

## 5.6. Compliance Plan

- 5.6.1. None

## **6.0 40 C.F.R. 60, Subpart KKKK Requirements for Turbines [emission point ID(s): E05, E06, E07, E08, and E09]**

### **6.1. Limitations and Standards**

- 6.1.1. NO<sub>x</sub> emissions from the Solar Taurus 60 Turbines (E05 & E06), Solar Mars Turbine (E08), and the Solar Taurus 70 Turbine (E09) shall not exceed 25 ppm at 15% O<sub>2</sub> (or an alternative limit of 150 ng/J of useful output). Additionally, for units less than or equal to 30 MW output, under low load (less than 75% of peak load) or low temperature (less than 0°F) conditions these turbines shall not exceed 150 ppm at 15 percent O<sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh)  
**[45CSR16; 40CFR§60.4320(a) and Table 1 of 40 C.F.R. 60 Subpart KKKK; 45CSR13, Permit R13-2715, Condition 4.1.14]**
- 6.1.2. The Solar Taurus 60 Turbines (E05 & E06), Solar Mars Turbine (E08), Solar Saturn 10 Turbine (E07) and the Solar Taurus 70 Turbine (E09) shall only burn fuel with a total potential SO<sub>2</sub> emission rate of less than 0.06 lb SO<sub>2</sub>/MMBTU heat input.  
**[45CSR16; 40CFR§60.4330(a)(2); 45CSR13, Permit R13-2715, Condition 4.1.16]**
- 6.1.3. The permittee must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.  
**[45CSR16; 40CFR§60.4333(a)]**
- 6.1.4. You must monitor the total sulfur content of the fuel being fired in the turbine, except as provided in §60.4365.  
**[45CSR16; 40CFR§60.4360]**
- 6.1.5. NO<sub>x</sub> emissions from the Solar Saturn 10 Turbine (E07) shall not exceed 150 ppm at 15% O<sub>2</sub> (or an alternative limit of 1,100 ng/J of useful output). Additionally, for units less than or equal to 30 MW output, under low load (less than 75% of peak load) or low temperature (less than 0°F) conditions these turbines shall not exceed 150 ppm at 15 percent O<sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh)  
**[45CSR16; 40CFR§60.4320(a) and Table 1 of 40 C.F.R. 60 Subpart KKKK; 45CSR13 Permit R13-2715, Condition 4.1.15]**

### **6.2. Monitoring Requirements**

- 6.2.1. You may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for units located in continental areas. You must use one of the following sources of information to make the required demonstration:
- The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet, has potential sulfur emissions of less than 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas; or
  - Representative fuel sampling data which show that the sulfur content of the fuel does not exceed 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.  
**[45CSR16; 40CFR§60.4365; 45CSR13, Permit R13-2715, Condition 4.3.10]**

### 6.3. Testing Requirements

6.3.1 (a) You must conduct an initial performance test, as required in §60.8. Subsequent NO<sub>x</sub> performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test).

(1) There are two general methodologies that you may use to conduct the performance tests. For each test run:

(i) Measure the NO<sub>x</sub> concentration (in parts per million (ppm)), using EPA Method 7E or EPA Method 20 in appendix A of this part. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then, use the following equation to calculate the NO<sub>x</sub> emission rate:

$$E = \frac{1.194 \times 10^{-7} * (NO_x)_c * Q_{std}}{P} \quad (\text{Eq. 5})$$

Where:

E = NO<sub>x</sub> emission rate, in lb/MWh

$1.194 \times 10^{-7}$  = conversion constant, in lb/dscf-ppm

(NO<sub>x</sub>)<sub>c</sub> = average NO<sub>x</sub> concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(ii) Measure the NO<sub>x</sub> and diluent gas concentrations, using either EPA Methods 7E and 3A, or EPA Method 20 in appendix A of this part. Concurrently measure the heat input to the unit, using a fuel flowmeter (or flowmeters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the NO<sub>x</sub> emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the NO<sub>x</sub> emission rate in lb/MWh.

(2) Sampling traverse points for NO<sub>x</sub> and (if applicable) diluent gas are to be selected following EPA Method 20 or EPA Method 1 (non-particulate procedures), and sampled for equal time intervals. The sampling must be performed with a traversing single-hole probe, or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

(3) Notwithstanding paragraph (a)(2) of this section, you may test at fewer points than are specified in EPA Method 1 or EPA Method 20 in appendix A of this part if the following conditions are met:

(i) You may perform a stratification test for NO<sub>x</sub> and diluent pursuant to

(A) [Reserved], or

(B) The procedures specified in section 6.5.6.1(a) through (e) of appendix A of part 75 of this chapter.

(ii) Once the stratification sampling is completed, you may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point  $\text{NO}_x$  concentrations is within  $\pm 10$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 5$  ppm or  $\pm 0.5$  percent  $\text{CO}_2$  (or  $\text{O}_2$ ) from the mean for all traverse points, then you may use three points (located either 16.7, 50.0 and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The three points must be located along the measurement line that exhibited the highest average  $\text{NO}_x$  concentration during the stratification test; or

(B) For turbines with a  $\text{NO}_x$  standard greater than 15 ppm @ 15%  $\text{O}_2$ , you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point  $\text{NO}_x$  concentrations is within  $\pm 5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 3$  ppm or  $\pm 0.3$  percent  $\text{CO}_2$  (or  $\text{O}_2$ ) from the mean for all traverse points; or

(C) For turbines with a  $\text{NO}_x$  standard less than or equal to 15 ppm @ 15%  $\text{O}_2$ , you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point  $\text{NO}_x$  concentrations is within  $\pm 2.5$  percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than  $\pm 1$  ppm or  $\pm 0.15$  percent  $\text{CO}_2$  (or  $\text{O}_2$ ) from the mean for all traverse points.

(b) The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. You may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. You must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes.

(1) If the stationary combustion turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

(2) For a combined cycle and CHP turbine systems with supplemental heat (duct burner), you must measure the total  $\text{NO}_x$  emissions after the duct burner rather than directly after the turbine. The duct burner must be in operation during the performance test.

(3) If water or steam injection is used to control  $\text{NO}_x$  with no additional post-combustion  $\text{NO}_x$  control and you choose to monitor the steam or water to fuel ratio in accordance with §60.4335, then that monitoring system must be operated concurrently with each EPA Method 20 or EPA Method 7E run and must be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.4320  $\text{NO}_x$  emission limit.

(4) Compliance with the applicable emission limit in §60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average  $\text{NO}_x$  emission rate at each tested level meets the applicable emission limit in §60.4320.

(5) If you elect to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in §60.4405) as part of the initial performance test of the affected unit.

(6) The ambient temperature must be greater than 0 °F during the performance test.  
**[45CSR16; 40CFR§§60.4400(a) and (b)]**

6.3.2 If you are not using water or steam injection to control NO<sub>x</sub> emissions, you must perform annual performance tests in accordance with 40CFR§60.4400 to demonstrate continuous compliance. If the NO<sub>x</sub> emission result from the performance test is less than or equal to 75 percent of the NO<sub>x</sub> emission limit for the turbine, you may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NO<sub>x</sub> emission limit for the turbine, you must resume annual performance tests.

**[45CSR16; 40CFR§60.4340(a); 45CSR13, R13-2175, Condition 4.2.1]**

#### **6.4. Recordkeeping Requirements**

6.4.1. N/A

#### **6.5. Reporting Requirements**

6.5.1. For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, you must submit reports of excess emissions and monitor downtime, in accordance with 40CFR§60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction.

**[45CSR16; 40CFR§60.4375(a) and 45CSR13, Permit R13-2715, Condition 4.4.1]**

6.5.2. For each affected unit that performs annual performance tests in accordance with 40CFR§60.4340(a), you must submit a written report of the results of each performance test before the close of business on the 60th day following the completion of the performance test.

**[45CSR16; 40CFR§60.4375(b) and 45CSR13, Permit R13-2715, Condition 4.4.1]**

6.5.3. All reports required under §60.7(c) must be postmarked by the 30th day following the end of each 6-month period.

**[45CSR16; 40CFR§60.4395]**

#### **6.6. Compliance Plan**

6.6.1. None